



**HIGH SPEED DOOR/RAPID ROLL
ELEVATION**

- SPECIFICATION**
 RAPID ROLL DOOR
 CLASS 2 WIND RESISTANT
 3 Phase 400v AC Worm Gear & Brake Motor
 Manual Override System
 Control Panel (OP55 Rated0
 4mm Thick PVC Door Curtain
 Vision Panel
 3mm Thick Mild Steel Guides
 Wild Bar System
 High Impact Resistance Bottom Rail
 Self Destructing Knock Out Tabs
 Canopy 20swg Powder Coated Mild Steel
 2No - 24volt DC Photo Electric Safety Beams
 Wireless Safety Edge System
 Radar Movement Sensor to Both Sides of Door
 Standard Colour Curtain - Powder Coated Frame
 Access Control System By Others
 HSD Weight = 35KG Per M2

< VERY IMPORTANT >
 All internal/external panels in way of shutters
MUST be easily removable to permit access to
full length of shutter barrel for
 adjustment, maintenance and repair.
 All manual over-ride positions
MUST be agreed by Architect **BEFORE**
 shutter installation.

CHECK YOUR SHUTTER SPECIFICATION 1ST
 1No 240v13amp switched fused spur is required for
Non Fire Rated Single Phase motors.
 Single Phase **Fire** Shutters require a N/O clean set
 of contacts to activate the fire panel plus 2No 240v
 13amp spurs, 1 for the motor & 1 for the fire panel.
 The fused spur is to be provided within 1M of the
 shutters at motor height.
 For each **3 Phase** Shutter we require 1No 16amp
 5pin 415v wall socket to be located at high level no
 more than 1m from the shutter motor. Three Phase
 shutters = 415v 16amp.
 The fused spur is to be provided within 1M of the
 shutters at motor height.
 This is to be completed prior to Armourpost's
 attendance.

09.05.23	PRELIMINARY ISSUE
REVISION	
DIMENSIONS OBTAINED FROM: AP SURVEY <input type="checkbox"/> AGREED <input type="checkbox"/> CLIENT <input type="checkbox"/> DESIGN <input type="checkbox"/>	



Saltmeadows Road, East Gateshead Industrial Estate
 Gateshead, Tyne & Wear. NE8 3AH
 Tel: 0191 478 7878 Fax: 0191 478 2588

SITE:
 THROUGHOUT THE UK

SHUTTER/DOOR REF:
 HIGH SPEED DOOR

LOCATION:
 X

BY: N.G.L. CHK BY:	DWG No: SK 01	REV No:
--------------------------	------------------	---------